



Wisconsin ENERGY STAR[®] Homes

Program Bulletin #2

Site Visit Changes

January 1, 2008

Please note the following changes to Site Visit 3 have been made and are on the web site:

1. As of January 1, 2008, it is no longer a **requirement** for Wisconsin **ENERGY STAR** Homes certification to do zone pressurization testing. It has been required but has **not** been a standard. Providing zone pressurization testing for your builder may still provide value related to the distribution system.
2. **Standard 1AQ** – A change has been made to reflect the need to specify a ‘remote mounted’ switch when a bath fan mounted in a bathroom is designed to provide both spot **and** whole house ventilation.

When this bath fan is the appliance providing the whole house ventilation and there is **no** remote switch, you must leave the REM/Rate whole house ventilation screen empty.

Any project included on your tracking spreadsheet as of January, 2008, **MUST** include this version of Site Visit 3.